## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

## FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM





**LISTING No.** 7167-1662:108 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: GE Interlogix, 2266 Second St. North, North Saint Paul, MN 55109

Contact: Rick Conner (651) 779-4824 FAX (651) 779-4884

**DESIGN**: Model 60-806-95R combination household fire and burglary fire alarm control units. Refer to

listee's data sheet for detailed product description and operational considerations. System

components:

60-806-95R Control Unit

60-836 SuperBus Voice Module

60-820 SuperBus 2000 Fixed Display Touchpad

60-756, -757, -758 Snap Card

60-822 Class II Transformer 60-746, -803, -809 LCD Touchpad

**INSTALLATION**: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

**MARKING**: Listee's name, model number, electrical rating and UL label.

**APPROVAL**: Listed as combination household fire and burglary alarm control unit for use with separately

listed compatible initiating and indicating devices.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition. Refer to manufacturer's

Installation Manual for details.

NOTE: 1. Burglary and other non-fire functions were not examined. Refer to listee's data sheet or

installation instructions for compatible non-fire devices.

2. Fire Alarm Verification Feature is NOT approved for use in California. This feature

shall not be programmed into the system.

3. RF (wireless) operating system is not approved.

**FORMERLY:** 7167-1604:110 and 7167-1126:119

08-31-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 26, 2008 Listing Expires June 30, 2009

Authorized By: **BEN HO**, Chief

Fire Engineering Division